


Quadro de Cargas (QM1)

Circuito	Descrição	Esquema	Módulo de Med.	Tensão (V)	Pot. total (VA)	Pot. total (kW)	Fases	Pot. - R (W)	Pot. - S (W)	Pot. - T (W)	FCT	FCA	IR (%)	Id (A)	Sigla (mm ²)	Lc (A)	Dsl (%)	dv/dtsec (%)	dv/total (%)	Status
OD1		3F+N+T	B1	380/220 V	53920	46,92	R-S-T	15193	18192	14947	1,00	0,30	118,8	82,1	50	134,0	100	0,47	0,31	OK
OD2		3F+N+T	B1	380/220 V	53053	37,03	R-S-T	11961	17803	13248	1,00	0,30	100,3	80,6	50	134,0	90	2,46	2,39	OK
TOTAL					112854	83,95	R-S-T	27154	29995	28195										

Quadro de Demanda (QM1)

Tipo	Potência instalada (kVA)	Fator de demanda (%)	Demanda (kVA)
Específico	112,85	100,00	112,85
TOTAL			112,85






PROJETO ESPECÍFICO CEALNOR

ELETRICO

PROJETO: QUADROS E DIAGRAMAS

PLANTA: TOMÁS SIMÕES CERQUEIRA

VERSÃO REVISADA EM:

NÚMERO: ELE. 03/03

DATA: AGOSTO - 2019

PROJETADE: SEM ESCOLA

REVISADO: SEM ESCOLA

PROJETADE: SEM ESCOLA